



- NOTES:
1. MANUFACTURED CONNECTIONS TO REINFORCED CONCRETE PIPE TO BE MADE USING APPROVED PVC SADDLES.
 2. CONNECTIONS TO BE 100 MINIMUM OR AS SPECIFIED ON CONTRACT DRAWINGS.
 3. RISER TYPE SERVICE TO BE USED ONLY WHEN SERVICE IS MORE THAN 2400 ABOVE WYE INVERT OR AS DIRECTED BY THE CONTRACT ADMINISTRATOR.
 4. LOCATION OF SERVICE AND MARKER AS SHOWN ON CONTRACT DRAWINGS.
 5. SEE DRAWING SS9 FOR DETAIL OF INSPECTION CHAMBER INSTALLATION REQUIREMENTS. PLUG IS NOT TO BE PROVIDED.

NOT TO SCALE

SANITARY SEWER SERVICE CONNECTION



No.	DATE	REVISION DESCRIPTION	BY	APP
4	APR2022	REVIEWED AND UPDATED 2022	IP	JDh
3	JAN2019	REVIEWED AND UPDATED 2019	DAR	JDh

DWG. No. **SS7**
REV. **4**

Canada's Tournament Capital