



- NOTES:
1. CONFIRM ELECTRICAL CONTINUITY BETWEEN TEE AND GATE VALVE.
INSTALL DOUBLE BONDS IF NOT ELECTRICALLY CONTINUOUS (SEE DRAWING SW107).
 2. CONFIRM FIRE HYDRANT RISER AND 90° BEND ARE ELECTRICALLY CONTINUOUS.
INSTALL DOUBLE BONDS IF NOT CONTINUOUS (SEE DRAWING SW107).
 3. STRUCTURE CABLES TO BE WRAPPED ONCE AROUND TEE AND GATE VALVE.
 4. ALL CABLES PARALLEL TO PIPE TO BE ATTACHED TO PIPE USING PIPELINE TAPE.
 5. INSTALL ANODE(S) IN LOCATIONS SPECIFIED IN CONTRACT AND PARALLEL TO PIPE.

NOT TO SCALE

No.	DATE	REVISION DESCRIPTION	BY	APP
3	APR2022	REVIEWED AND UPDATED 2022	IP	CM
2	MAY2019	REVIEWED AND UPDATED 2019	DAR	CM

HYDRANT CATHODIC PROTECTION



DWG. No. SW119
REV. 3