



- NOTES:
1. THIS DETAIL FOR SERVICES 25 TO 50 ONLY.
 2. ALL SERVICE SADDLES ARE TO BE STAINLESS STEEL TYPE 304/314L WITH DOUBLE BOLT CLOSURES OR STAINLESS STEEL DOUBLE STRAP SADDLE WITH EACH STRAP MINIMUM 45 WIDTH.
 3. ALL CURB STOPS ARE TO BE NON-DRAINING, FULL FLOW, FULL PORT, BALL TYPE.
 4. TRACER WIRES MUST BE INSTALLED ON ALL SERVICES LONGER THAN 20m AND ALL SERVICES THAT ARE NOT PERPENDICULAR TO BOTH THE WATERMAIN AND PROPERTY LINE.
 5. SERVICE TUBING TO BE CONTINUOUS (JOINT FREE) BETWEEN THE CORPORATION STOP AND CURB STOP.
 6. REFER TO CONTRACT DRAWINGS AND SECTION 33 11 01 FOR DETAILED SPECIFICATIONS.

NOT TO SCALE

| No. | DATE | REVISION DESCRIPTION | BY | APP |
|-----|---------|---------------------------|-----|-----|
| 7 | JUN2022 | UPDATED MATERIALS | JK | JDh |
| 6 | MAR2022 | REVIEWED AND UPDATED 2022 | IP | JDh |
| 5 | FEB2019 | REVIEWED AND UPDATED 2019 | DAR | JDh |

WATER SERVICE CONNECTION 25-50mmø



REV. No. 7
 DWG. No. SW2