



KAP 99999

PLAN

- NOTES:
1. LOT SEWER SERVICES TO BE 3000 MINIMUM FROM LOT CORNER PIN IN CUL-DE-SAC.
 2. STORM AND SANITARY SERVICES TO BE DOWNHILL SIDE OF THE WATER SERVICE.
 3. VAULTS, SERVICE BOXES, ETC. NOT BE LOCATED IN SIDEWALKS WITHOUT CITY APPROVAL.
 4. REFER TO CONTRACT DRAWINGS AND SECTIONS 33 40 01, 32 11 23, 32 11 16.1, 31 22 16.1, 32 12 16, SS7, SS8, SS9, AND SW2 FOR DETAILED SPECIFICATIONS.
 5. TRACER WIRES MUST BE INSTALLED ON ALL SERVICES LONGER THAN 20m AND ALL SERVICES THAT ARE NOT PERPENDICULAR TO BOTH THE WATERMAIN AND PROPERTY LINE.
 6. WHERE WALKWAY PRESENT SIDEWALK SHALL EXTEND TO PROVIDE CONNECTIVITY TO WALKWAY.

NOT TO SCALE

| No. | DATE | REVISION DESCRIPTION | BY | APP |
|-----|---------|---------------------------|-----|-----|
| 4 | AUG2022 | REVISED | JH | JDh |
| 3 | APR2022 | REVIEWED AND UPDATED 2022 | IP | JDh |
| 2 | FEB2019 | REVIEWED AND UPDATED 2019 | DAR | JDh |

UTILITY SERVICING IN A CUL-DE-SAC



DWG. No. REV. 4
SG10