



- NOTES: 1. REFER TO SUPPLEMENTARY SPECIFICATIONS FOR HYDRANT PAINTING REQUIREMENTS.  
 2. REFER TO CONTRACT DRAWINGS AND SECTION 33 11 01 FOR DETAILED SPECIFICATIONS.  
 3. REFER TO CITY OF KAMLOOPS BYLAW 10-37 (SECTIONS 413 TO 416) FOR HYDRANT CLEAR ZONES REQUIREMENTS. (TYPICALLY 1500 MIN. ALL AROUND)  
 4. VERTICAL BENDS OR DEFLECTIONS ARE NOT PERMITTED.

NOT TO SCALE

No.	DATE	REVISION DESCRIPTION	BY	APP
8	NOV2022	REVIEWED AND UPDATED 2022	TL	JDh
7	OCT2022	REVIEWED AND UPDATED 2022	MB	JDh
6	APR2022	REVIEWED AND UPDATED 2022	IP	JDh
5	FEB2019	REVIEWED AND UPDATED 2019	DAR	JDh

## FIRE HYDRANT ASSEMBLY



REV. No. 8  
 DWG. No. SW4