



- NOTE:
1. PIPE AND FITTINGS TO BE EITHER BRASS OR SCHEDULE 80 PVC.
 2. PIPE SIZES TO BE DETERMINED FOR SPECIFIC PROJECT APPLICATION.
 3. INSTALLATION IN STANDARD IRRIGATION BOXES OR CONCRETE VAULT c/w NON SLIP LID IN PEDESTRIAN AREAS.
 4. EASE OF ACCESS MUST BE CONSIDERED WHEN INSTALLING.
 5. ALL CHANGES NEED APPROVAL FROM CITY OF KAMLOOPS.
 6. PROVIDE WATER METER TAG NUMBER TO CITY OF KAMLOOPS.

NOT TO SCALE

No.	DATE	REVISION DESCRIPTION	BY	APP
1	MAR2023	RECONFIGURATION	DAR	Jdh

IRRIGATION POINT OF CONNECTION



DWG. No. SW14
 REV. 1