



- NOTE:
1. THE STATION SHALL BE MODEL #66-XC FOR EXTREME COLD CLIMATES AS MANUFACTURED BY THE KUPFERLE FOUNDRY, ST. LOUIS MO. OR APPROVED EQUAL c/w COLD WEATHER PACKAGE.
 2. PASSIVATION PROCESS FOR ADDITIONAL CORROSION PROTECTION IS REQUIRED FOR ALL STAINLESS STEEL PARTS.
 3. ALL FITTINGS TO BE STAINLESS STEEL.
 4. PROTECT STATION WITH CONCRETE BARRIER, BARRIER POSTS OR OTHER MEANS AS PER CONTRACT DRAWINGS.

No.	DATE	REVISION DESCRIPTION	BY	APP

PERMANENT WATER SAMPLING STATION



Canada's Tournament Capital

DWG. No. SW12
REV. 0